



Residential Air Sealing Installation Certificate

Office Use Only
Reviewed by: _____
Date: _____

Complete form and sign/date. All information is required to process rebate(s).
Certificate must accompany the Residential Weatherization Rebate Application. Offered to Ukiah Electric Utility UEU residential customers with an active UEU account.

CUSTOMER INFORMATION

Customer Name					
Installation Address					
City		State		Zip	

CONTRACTOR INFORMATION

Company Name	Technician Name
Address	
City	State
Zip	Zip

EQUIPMENT INFORMATION

Blower Door Manufacturer	Model Number
---------------------------------	---------------------

HOME INFORMATION

House Type	Square Feet	Ceiling Height	Building Volume	Number of Levels	Combustion Appliance(s) Present	UL-Listed CO Detector Installed
<input type="checkbox"/> Site Built					<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
<input type="checkbox"/> Manufactured Home						

AIR SEALING TEST INFORMATION

Blower door test data must be entered before and after air sealing to show a **30% or greater reduction** in air leakage.

	House Pressure (Pa)	Fan Configuration (Rings or other restrictors)	Fan Pressure	Can't Reach 50 Factor	House Leakage Rate
PRE-TEST					
POST-TEST					

Leakage reduction (Pre-test – Post-test)	CFM₅₀
% Reduction (Leakage Reduction / Pre-test x 100) <i>CFM Reduction must be 30% or Greater to qualify for a Rebate.</i>	%

List in detail which air sealing measures were installed (i.e., sealed bypasses, plumbing/electrical penetrations in wall, attic, floor, etc.):

Testing and Sealing must meet the following minimum requirements:

- Equipment and gauges must be maintained and calibrated according to manufacturers' recommendations. Technicians may be required to show evidence of required maintenance or calibration procedures.
- House leakage must be tested and reported in CFM, at a house pressure of 50 Pa with respect to outdoors. If the house cannot be pressurized to 50 Pa, a lower pressure may be used and multiplied by a "can't reach 50" factor supplied by the equipment manufacturer. The "can't reach 50" multiplier must be shown on this form.
- Test procedures must be conducted by a certified HERS Rater, or BPI Technician, or as approved by the utility.
- Testing and sealing must be performed in accordance with HERS, or BPI standards. Mechanical ventilation may be required.

I certify that the test data is accurate and that measurements were done in compliance with the standards applicable to the certification below.

Certification Number: _____ **Type:** HERS BPI

CONTRACTOR SIGNATURE _____ **DATE** _____