

September 30, 2024

The City of Ukiah has completed the initial lead service line inventory that is required by U.S. EPA's Lead and Copper Rule Revisions. The deadline for the initial inventory is October 16, 2024.

Through completing a historical records review and field investigations, the City of Ukiah has determined it has no lead or galvanized service lines requiring replacement in its distribution system. This includes any privately-owned or customer-owned service lines.

We reviewed all applicable sources of information available, including:

- All construction and plumbing codes, permits, and existing records or other documentation which indicates the service line materials;
- All water system records, including distribution system maps and drawings, historical records on each service connection, meter installation records, historical capital improvement or master plans, and standard operating procedures;
- All inspections and records of the distribution system that indicate service line material, including inspections conducted during the course of normal operations (e.g., checking service line materials when reading water meters or performing maintenance activities); and
- All previous service line or meter replacements were conducted.

In addition to reviewing the above sources of information, the City of Ukiah physically inspected all service lines in its distribution system, regardless of ownership. All service lines were verified **non-lead** copper, plastic, steel and galvanized.

We will continue to update service line material information obtained from normal operations, such as service line maintenance, installation, or water meter readings, after October 2024 and will update the initial inventory accordingly.

If you have any questions regarding this inventory or would like to know specific information regarding your service, contact Shelly Wagenet at the Water Treatment Plant.

Shelly Wagenet
Water Treatment Plant Supervisor
(707) 467-2842
mwagenet@cityofukiah.com